

DRINKING WATER NOTICE

HOLGATE VILLAGE Has Levels of TTHM above Drinking Water Standards

Our water system recently violated the maximum contaminant level (MCL) for TTHM. The average level of TTHM over the last four quarters is 0.085 mg/L at DS201 and 0.088 mg/L at DS202. The standard for TTHM is 0.080 mg/L.

What should I do?

- **You do not need to use an alternative (e.g. bottled) water supply.** However, if you have specific health concerns, consult your doctor.

What does this mean?

The levels detected do not pose an immediate risk to your health. Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous systems, and may have an increased risk of getting cancer.

What is being done?

We are investigating and taking the following necessary steps:

We are under construction for the water main from Napoleon, OH. to
Holgate, OH. To get off the wells and onto Napoleon
water. to correct
the problem as soon as possible.

Additional information may be obtained by contacting:

Contact Person: Jason Michel

Phone Number: 419-604-0145

Mailing Address: P.O. Box 212, Holgate, OH 43527

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

Date Distributed: October 13th

PWSID: OH3500512 Facility ID: DS1

Monitoring Period: Third Quarter of 2026